



Test Report: DRC-40B

40W Single Output With Battery Charger(UPS Function)

■ DESIGN VERIFY TEST

Output Function Test

Input Function Test

Protection Function Test

Control Function Test

Component Stress Test

■ SAFETY & E.M.C. TEST

Safety Test

E.M.C. Test

■ RELIABILITY TEST

ENVIRONMENT TEST

■ DESIGN VERIFY TEST

OUTPUT FUNCTION TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	RIPPLE & NOISE	V1 : 200 mVp-p (Max)	I/P : 230VAC O/P : FULL LOAD Ta : 25°C	V1 : 13.4 mVp-p (Max)	P
2	OUTPUT VOLTAGE ADJUST RANGE	CH1 : 24 V ~ 30V	I/P : 230 VAC I/P : 115 VAC O/P : MIN LOAD Ta : 25°C	22.89 V~ 31.54 V/ 230 VAC 22.89 V~ 31.54 V/ 115 VAC	P
3	OUTPUT VOLTAGE TOLERANCE	V1 : 1%~ -1 % (Max)	I/P : 90 VAC / 264 VAC O/P : FULL/ MIN LOAD Ta : 25°C	V1 : -0.043 %~ 0.065 %	P
4	LINE REGULATION	V1 : 0.5 %~ -0.5 % (Max)	I/P : 90VAC ~ 264 VAC O/P : FULL LOAD Ta : 25°C	V1 : 0 %~ 0 %	P
5	LOAD REGULATION	V1 : 0.5 %~ -0.5 % (Max)	I/P : 230 VAC O/P : FULL ~MIN LOAD Ta : 25°C	V1 : -0.043 %~ 0.065 %	P
6	SET UP TIME	230VAC : 400 ms (Max) 115VAC : 800 ms(Max) 800	I/P : 230 VAC I/P : 115 VAC O/P : FULL LOAD Ta : 25°C	230VAC/ 275.118 ms 115VAC/ 604.200 ms	P
7	RISE TIME	230VAC : 50 ms (Max) 115VAC : 50 ms (Max)	I/P : 230 VAC I/P : 115 VAC O/P : FULL LOAD Ta : 25°C	230VAC/ 16.663 ms 115VAC/ 15.165 ms	P
8	HOLD UP TIME	230VAC : 50 ms (TYP) 115VAC : 10 ms (TYP)	I/P : 230 VAC I/P : 115 VAC O/P : FULL LOAD Ta : 25°C	230VAC/ 74.935 ms 115VAC/ 16.136 ms	P
9	OVER/UNDERSHOOT TEST	< +5%	I/P : 230 VAC O/P : FULL LOAD Ta : 25°C	TEST : <5 %	P
10	DYNAMIC LOAD	V1 : 2760 mVp-p	I/P : 230 VAC (1).O/P : FULL /Min LOAD 90%DUTY/ 1KHZ (2).O/P : FULL /Min LOAD 90%DUTY/ 3KHZ (3).O/P : FULL /Min LOAD 90%DUTY/ 5KHZ (4).O/P : FULL /Min LOAD 50%DUTY/ 120HZ Ta : 25°C	(1)183 mVp-p (2)113 mVp-p (3)99.0 mVp-p (4)196 mVp-p	P

INPUT FUNCTION TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
----	-----------	---------------	----------------	--------	---------

1	INPUT VOLTAGE RANGE	90VAC~264VAC 127VDC ~ 370VDC	(1) I/P:TESTING O/P:FULL LOAD (2) I/P:DC TESTING(L:+ N:-) O/P: FULL / 50% LOAD (3) I/P:DC TESTING(L:- N:+) O/P: FULL / 50% LOAD Ta : 25°C	(1) 71.037V~264V (2) 115.36Vdc~370Vdc/FULL LOAD 115.35Vdc~370Vdc/50% LOAD (3) 115.35Vdc~370Vdc/FULL LOAD 115.34Vdc~370Vdc/50% LOAD	P
			I/P : (1)LOW-LINE-3V=87 V HIGH-LINE+15%=300 V O/P: 75%/MIN LOAD ON: 30 Sec OFF: 30 Sec 10MIN (2)230Vac ON: 0.5 Sec OFF: 0.5 Sec 20MIN (3)230Vac ON:3Sec OFF:3Sec 12HOURS (POWER ON/OFF NO DAMAGE)	TEST : (1) OK (2)OK (3)OK	
2	INPUT FREQUENCY RANGE	47HZ ~63 HZ NO DAMAGE	I/P : 90 VAC ~ 264 VAC O/P : FULL~MIN LOAD Ta : 25°C	TEST : OK	P
3	EFFICIENCY	87% (TYP)	I/P : 230 VAC O/P : FULL LOAD Ta : 25°C	87.35 %	P
4	INPUT CURRENT	230V/ 0.6 A (TYP) 115V/ 0.8 A (TYP)	I/P : 230 VAC I/P : 115 VAC O/P : FULL LOAD Ta : 25°C	I = 0.39 A/ 230 VAC I = 0.70 A/ 115 VAC	P
5	INRUSH CURRENT	230V/ 60 A (TYP) 115V/ 30 A(TYP) COLD START	I/P : 230 VAC I/P : 115 VAC O/P : FULL LOAD Ta : 25°C	I = 49.257 A/ 230 VAC I = 29.648 A/ 115 VAC	P


PROTECTION FUNCTION TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	OVER LOAD PROTECTION	105 % ~ 150 %	I/P : 230 VAC I/P : 115 VAC O/P : TESTING Ta : 25°C	131.72 %/ 230 VAC 129.31%/ 115 VAC Protection type : Hiccup mode, recovers automatically after fault condition is removed	P
2	OVER VOLTAGE PROTECTION	CH1 : 28.98 V ~ 37.26 V	I/P : 230 VAC I/P : 115 VAC O/P : MIN LOAD Ta : 25°C	33.37V/ 230 VAC 33.42V/ 115 VAC Protection type : Shut down o/p voltage, re-power on to recover	P
3	SHORT PROTECTION	SHORT EVERY OUTPUT 1 HOUR NO DAMAGE	I/P : 264 VAC O/P : FULL LOAD Ta : 25°C	NO DAMAGE Hiccup Mode, recovers automatically after fault condition is removed	P
4	BATTERY CUT OFF	20±1V	I/P : 230 VAC O/P : MIN LOAD Ta : 25°C	20.638V/230VAC	P

CONTROL FUNCTION TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	AC OK	TTL OPEN COLLECTOR OUTPUT ON:AC OK OFF:AC FAIL MAX RATING:50V/30mA	I/P : 230 VAC O/P : FULL LOAD Ta : 25°C	OK :AC OK OK :AC ICE	P
2	BATTERY LOW	TTL OPEN COLLECTOR OUTPUT OFF :BATTERY OK ON :BATTERY LOW MAX RATING: 50V/30mA BATTERY LOW VOLTAGE:<22V	I/P : 230 VAC O/P : FULL LOAD Ta : 25°C	OK :BATTERY OK OK :BATTERY LOW 20.68:BATTERY LOW VOLTAGE	P

COMPONENT STRESS TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	Power Transistor (D to S) or (C to E) Peak Voltage	Q1 Rated :  10A 600V	I/P : High-Line +3V = 267 V O/P : (1)Full Load Turn on (2) Output Short (3)Full load continue Ta : 25°C	(1) 476 V (2) 406 V (3) 476 V	P
2	Diode Peak Voltage	D100 Rated : BYQ28X-200: 10A/200V	I/P : High-Line +3V = 267 V O/P : (1)Full Load Turn on (2)Output Short (3)Full load continue Ta : 25°C	(1) 133 V (2) 111 V (3) 134 V	P
3	Input Capacitor Voltage	C 5 Rated :	I/P : High-Line +3V = 267 V	(1) 366 V	P

		68u/400V 105°C 18*25 KMX Surge Voltage:450V	O/P : (1)Full Load Turn on /Off (2) Min load Turn on /Off (3)Full Load /Min load Change Ta : 25°C	(2) 364 V (3) 368 V	
4	Control IC Voltage Test	U1 Rated : NC, D, S, B, R, C, 9, 4, 1, 2, 3, 1	I/P : High-Line +3V = 267 V O/P : (1)Full Load Turn on /Off (2) Min load Turn on /Off (3)Full Load /Min load Change Ta : 25°C	(1) 17.0 V (2) 17.0 V (3) 10.8 V	P

SAFETY & E.M.C. TEST

SAFETY TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	WITHSTAND VOLTAGE	I/P-O/P : 3 KVAC/min I/P-FG : 2 KVAC/min O/P-FG : 0.5 KVAC/min	I/P-O/P : 3.6 KVAC/min I/P-FG : 2.4KVAC/min O/P-FG : 0.6 KVAC/min Ta : 25°C	I/P-O/P : 2.086 mA I/P-FG : 1.642 mA O/P-FG : 0.671 mA NO DAMAGE	P
2	ISOLATION RESISTANCE	I/P-O/P : 500VDC>100MΩ I/P-FG : 500VDC>100MΩ O/P-FG : 500VDC>100MΩ	I/P-O/P : 500 VDC I/P-FG : 500 VDC O/P-FG : 500 VDC Ta : 25°C /70%RH	I/P-O/P : 407 GΩ I/P-FG : 222 GΩ O/P-FG : 391 GΩ NO DAMAGE	P
3	GROUNDING CONTINUITY	FG(PE) TO CHASSIS OR TRACE < 100 mΩ	40 A / 2min Ta : 25°C / 70%RH	3mΩ	P

E.M.C TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	HARMONIC	BS EN/EN61000-3-2 CLASS A	I/P:230VAC/50HZ O/P:100%OAD Ta:25°C	PASS	P
2	CONDUCTION	BS EN/EN55032 (CISPR32) CLASS B	I/P : 230 VAC (50HZ) O/P : FULL/50% LOAD Ta : 25°C	PASS Test by certified Lab	P
3	RADIATION	BS EN/EN55032 (CISPR32) CLASS B	I/P : 230 VAC (50HZ) O/P : FULL LOAD Ta : 25°C	PASS Test by certified Lab	P
4	E.S.D	BS EN/EN61000-4-2 LIGHT INDUSTRY AIR : 8KV / Contact : 4KV	I/P : 230 VAC/50HZ O/P : FULL LOAD Ta : 25°C	CRITERIA A	P
5	E.F.T	BS EN/EN61000-4-4 LIGHT INDUSTRY INPUT : 1KV	I/P : 230 VAC/50HZ O/P : FULL LOAD Ta : 25°C	CRITERIA A	P
6	SURGE	BS EN/EN61000-4-5 LIGHT INDUSTRY L-N : 1KV L,N-PE : 2KV	I/P : 230 VAC/50HZ O/P : FULL LOAD Ta : 25°C	CRITERIA A	P
7	Test by certified Lab & Test Report Prepare				

■ **RELIABILITY TEST**

ENVIRONMENT TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT																																																																				
1	TEMPERATURE RISE TEST	MODEL : DRC-40A 1. ROOM AMBIENT BURN-IN : 1HRS I/P : 230VAC O/P : FULL LOAD Ta=28.6°C 2. HIGH AMBIENT BURN-IN : 1 HRS I/P : 230VAC O/P : FULL LOAD Ta=51.5°C	<table border="1"> <thead> <tr> <th>NO</th> <th>Position</th> <th>ROOM AMBIENT Ta=28.6°C</th> <th>HIGH AMBIENT Ta=51.5°C</th> </tr> </thead> <tbody> <tr><td>1</td><td>L101</td><td>62.7°C</td><td>81.0°C</td></tr> <tr><td>2</td><td>BD1</td><td>53.7°C</td><td>73.6°C</td></tr> <tr><td>3</td><td>LF1</td><td>50.3°C</td><td>72.1°C</td></tr> <tr><td>4</td><td>D5</td><td>72.7°C</td><td>94.4°C</td></tr> <tr><td>5</td><td>Q1</td><td>61.7°C</td><td>82.7°C</td></tr> <tr><td>6</td><td>T1</td><td>83.0°C</td><td>99.7°C</td></tr> <tr><td>7</td><td>C106</td><td>74.4°C</td><td>92.7°C</td></tr> <tr><td>8</td><td>D100</td><td>85.0°C</td><td>101.6°C</td></tr> <tr><td>9</td><td>L100</td><td>61.2°C</td><td>81.0°C</td></tr> <tr><td>10</td><td>U1</td><td>69.1°C</td><td>87.8°C</td></tr> <tr><td>11</td><td>U200</td><td>66.7°C</td><td>85.0°C</td></tr> <tr><td>12</td><td>C5</td><td>49.0°C</td><td>68.5°C</td></tr> <tr><td>13</td><td>C36</td><td>65.4°C</td><td>84.0°C</td></tr> <tr><td>14</td><td>C200</td><td>71.7°C</td><td>89.2°C</td></tr> <tr><td>15</td><td>RY1</td><td>65.7°C</td><td>84.2°C</td></tr> <tr><td>16</td><td>RY2</td><td>60.3°C</td><td>78.5°C</td></tr> </tbody> </table>	NO	Position	ROOM AMBIENT Ta=28.6°C	HIGH AMBIENT Ta=51.5°C	1	L101	62.7°C	81.0°C	2	BD1	53.7°C	73.6°C	3	LF1	50.3°C	72.1°C	4	D5	72.7°C	94.4°C	5	Q1	61.7°C	82.7°C	6	T1	83.0°C	99.7°C	7	C106	74.4°C	92.7°C	8	D100	85.0°C	101.6°C	9	L100	61.2°C	81.0°C	10	U1	69.1°C	87.8°C	11	U200	66.7°C	85.0°C	12	C5	49.0°C	68.5°C	13	C36	65.4°C	84.0°C	14	C200	71.7°C	89.2°C	15	RY1	65.7°C	84.2°C	16	RY2	60.3°C	78.5°C		P
NO	Position	ROOM AMBIENT Ta=28.6°C	HIGH AMBIENT Ta=51.5°C																																																																						
1	L101	62.7°C	81.0°C																																																																						
2	BD1	53.7°C	73.6°C																																																																						
3	LF1	50.3°C	72.1°C																																																																						
4	D5	72.7°C	94.4°C																																																																						
5	Q1	61.7°C	82.7°C																																																																						
6	T1	83.0°C	99.7°C																																																																						
7	C106	74.4°C	92.7°C																																																																						
8	D100	85.0°C	101.6°C																																																																						
9	L100	61.2°C	81.0°C																																																																						
10	U1	69.1°C	87.8°C																																																																						
11	U200	66.7°C	85.0°C																																																																						
12	C5	49.0°C	68.5°C																																																																						
13	C36	65.4°C	84.0°C																																																																						
14	C200	71.7°C	89.2°C																																																																						
15	RY1	65.7°C	84.2°C																																																																						
16	RY2	60.3°C	78.5°C																																																																						
2	OVER LOAD BURN-IN TEST	NO DAMAGE 1 HOUR (MIN)	I/P : 230 VAC O/P : 130% LOAD Ta : 25°C	TEST : OK	P																																																																				
3	LOW TEMPERATURE TURN ON TEST	TURN ON AFTER 2 HOUR	I/P : 264VAC/100VAC O/P : 100 % LOAD Ta=-20°C	TEST : OK	P																																																																				
4	HIGH HUMIDITY HIGH TEMPERATURE HIGH VOLTAGE TURN ON TEST	AFTER 12 HOURS IN CHAMBER ON CONTROL 55°C NO DAMAGE	I/P : 272 VAC O/P : FULL LOAD Ta=55°C HUMIDITY= 95%R.H	TEST : OK	P																																																																				
5	TEMPERATURE COEFFICIENT	±0.03%/°C (0~50°C)	I/P : 230 VAC O/P : FULL LOAD	±0.003%/°C (0~50°C)	P																																																																				
6	STORAGE TEMPERATURE TEST	1. Thermal shock Temperature : -40°C~ +80°C 2. Temperature change rate : 25°C / MIN 3. Dwell time low and high temperature : 30 MIN/EACH 4. Total test cycle : 5 CYCLE 5. Input/Output condition : STATIC		OK	P																																																																				
7	THERMAL SHOCK TEST	1. Thermal shock Temperature : -30°C~ +70°C 2. Temperature change rate : 25°C / MIN 3. Dwell time low and high temperature : 30 MIN/EACH 4. Total test cycle : 10 CYCLE 5. Input/Output condition : 230VAC/Full Load AC ON/OFF TEST turn on 58sec ; turn off 2sec		OK	P																																																																				



8	VIBRATION TEST	1 Carton & 1 Set (1) Waveform : Sine Wave (2) Frequency : 10~500Hz (3) Sweep Time : 12min/sweep cycle (4) Acceleration : 2G (5) Test Time : 60min in each axis (X.Y.Z) (6) Ta : 25°C	TEST : OK	P
9	CAPACITOR LIFE CYCLE	SUPPOSE C106 IS THE MOST CRITICAL COMPONENT (1) I/P : 230VAC O/P : FULL LOAD Ta=25°C LIFE TIME (2) I/P : 230VAC O/P : FULL LOAD Ta=55°C LIFE TIME (3) I/P : 230VAC O/P : 75% LOAD Ta=55°C LIFE TIME (4) I/P : 230VAC O/P : 50% LOAD Ta=55°C LIFE TIME	(1) 131182HRS (2) 31876HRS (3) 51124HRS (4) 68901HRS	P
10	MTBF	2496.2K hrs min. Telcordia SR-332 (Bellcore) ; 536.6K hrs min. MIL-HDBK-217F (25°C)		P
11	DMTBF/Accelerated Life Test	Demonstration Mean Time Between Failure (Expected Life): Above 50,000 hours @ TA 50°C		P

SAMPLE	TESTER	APPROVAL
PRODUCT SAMPLE	FRANK	WANGDZ

2007/3/20 A50-S014