



Test Report : MDS15C-24

15W 2"x1" Package Medical Grade DC-DC Converter

■ DESIGN VERIFY TEST

Output Function Test

Input Function Test

Protection Function Test

■ SAFETY TEST

Safety Test

■ RELIABILITY TEST

Environment Test

Other

DESIGN VERIFY TEST

OUTPUT FUNCTION TEST

NO	TEST ITEM	SPECICATION	TEST CONDITION	RESULT	VERDICT
1	VOLTAGE ACCURACY	-1.0% ~ +1.0 % (Max)	I/P:48VDC O/P:FULL LOAD Ta:25°C	+0.09%	P
2	RIPPLE & NOISE	60 mVp-p (Max)	I/P:48VDC O/P:FULL LOAD Ta:25°C	11 mV	P
3	LINE REGULATION	-0.5% ~ +0.5% (Max)	I/P:36VDC~75VDC O/P:FULL LOAD Ta:25°C	+0.00% ~ +0.00%	P
4	LOAD REGULATION	-0.5% ~ +0.5% (Max)	I/P:48VDC O/P:5% LOAD~FULL LOAD Ta:25°C	-0.01% ~ +0.01%	P

INPUT FUNCTION TEST

NO	TEST ITEM	SPECICATION	TEST CONDITION	RESULT	VERDICT
1	INPUT VOLTAGE RANGE	36 VDC ~ 75 VDC	I/P:TESTING O/P:FULL LOAD Ta:25°C	33.6 VDC ~ 75 VDC	P
2	EFFICIENCY	88% (Typ)	I/P:48VDC O/P:FULL LOAD Ta:25°C	89.69%	P
3	DC CURRENT	360 mA / FULL LOAD 5 mA / NO LOAD	I/P:48VDC O/P:NO / FULL LOAD Ta:25°C	346 mA / FULL LOAD 4.5 mA / NO LOAD	P

PROTECTION FUNCTION TEST

NO	TEST ITEM	SPECICATION	TEST CONDITION	RESULT	VERDICT
1	SHORT PROTECTION	CONTINUOUS	I/P:75VDC O/P:FULL LOAD Ta:25°C	HICCUP MODE AUTO-RECOVER	P
2	OVER LOAD PROTECTION	110% ~ 185% (Typ)	I/P:48VDC O/P:TESTING Ta:25°C	172.8% HICCUP MODE AUTO-RECOVER	P

SAFETY TEST

SAFETY TEST

NO	TEST ITEM	SPECICATION	TEST CONDITION	RESULT	VERDICT
1	WITHSTAND VOLTAGE	I/P-O/P:4.0K VAC/min	I/P-O/P:4.0K VAC/min Ta:25°C	I/P-O/P: 0.002mA NO DAMAGE	P
2	ISOLATION RESISTANCE	I/P-O/P:500VDC>100MΩ	I/P-O/P:500 VDC Ta:25°C	I/P-O/P>100MΩ NO DAMAGE	P

■ RELIABILITY TEST

ENVIRONMENT TEST

NO	TEST ITEM	SPECICATION	TEST CONDITION	RESULT	VERDICT									
1	TEMPERATURE RISE TEST	1. ROOM AMBIENT BURN-IN : 8HRS I/P:48VDC O/P:FULL LOAD Ta=25°C 2. HIGH AMBIENT BURN-IN : 8HRS I/P:48VDC O/P:FULL LOAD Ta=65°C 3. HIGH AMBIENT BURN-IN : 8HRS I/P:48VDC O/P:50% LOAD Ta=85°C			P									
		<table border="1"> <thead> <tr> <th>NO</th> <th>Position</th> <th>1</th> <th>2</th> <th>3</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>CASE</td> <td>52.7°C</td> <td>88.8°C</td> <td>107.2°C</td> </tr> </tbody> </table>	NO	Position		1	2	3	1	CASE	52.7°C	88.8°C	107.2°C	
NO	Position	1	2	3										
1	CASE	52.7°C	88.8°C	107.2°C										
2	LOW TEMPERATURE TURN ON TEST	TURN ON AFTER 4 HOURS	I/P:48VDC O/P: FULL LOAD Ta= -40°C	TEST : OK	P									

OTHER

NO	TEST ITEM	SPECICATION	TEST CONDITION	RESULT	VERDICT
1	MTBF	MIL-HDBK-217F,GB,25°C TOTAL FAILURE RATE : 0.943396 M.T.B.F : 1060 KHRS			P

TEST RESULT	TESTER	APPROVAL
PASS	ARCHEN HSIAO	PETER CHENG