

# CERTIFICATE

Issued to:  
Applicant:  
**MEAN WELL Enterprises Co., Ltd.**  
No.28, Wuquan 3rd Rd, Wugu District  
24891 New Taipei City, Taiwan

Licensee:  
**MEAN WELL Enterprises Co., Ltd.**  
No.28, Wuquan 3rd Rd, Wugu District  
24891 New Taipei City, Taiwan

Product : Switching Power supply  
Trade name(s) : MEAN WELL  
Type(s)/model(s) : NPB-x-yz (x=120, 240 or 360; y=12,24 or 48; z=AD1, XLR or TB)

The product and any acceptable variation thereof as specified in the Annex to this certificate and the documents referred to therein.

DEKRA hereby declares that the above-mentioned product has been certified based on:

- a type test according to EN 62368-1:2014 and EN 62368-1:2014/A11:2017
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 6059480


DEKRA hereby grants the right to use the DEKRA Mark.

The DEKRA Mark may be applied to the product as specified in this certificate for the duration and under the conditions of the DEKRA Mark certification agreement.

This certificate is issued on 25 May 2024 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 35-118966 REV.2

DEKRA Certification B.V.



B.T.M. Holtus  
Managing Director



K. Lin  
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE  
DUTCH ACCREDITATION  
COUNCIL



35-118966

**SPECIFICATION OF THE CERTIFIED PRODUCT****Product data**

Product	: Switching Power supply
Trade name(s)	: MEAN WELL
Type(s)/model(s)	: NPB-120-12z, NPB-120-24z, NPB-120-48z, NPB-240-12z, NPB-240-24z, NPB-240-48z, NPB-360-12z, NPB-360-24z and NPB-360-48z
Rated input voltage	: 100-240Vac
Rated frequency	: 50/60 Hz

**Product data – type NPB-120-12z**

Rated output voltage	: 14,4 Vdc
Rated input current	: 1,5 A
Rated output current	: 6,8 A

**Product data – type NPB-120-24z**

Rated output voltage	: 28,8 Vdc
Rated input current	: 1,5 A
Rated output current	: 4 A

**Product data – type NPB-120-48z**

Rated output voltage	: 57,6 Vdc
Rated input current	: 1,5 A
Rated output current	: 2 A

**Product data – type NPB-240-12z**

Rated output voltage	: 14,4 Vdc
Rated input current	: 3,0 A
Rated output current	: 13,5 A

**Product data – type NPB-240-24z**

Rated output voltage	: 28,8 Vdc
Rated input current	: 3,0 A
Rated output current	: 8 A

**Product data – type NPB-240-48z**

Rated output voltage	: 57,6 Vdc
Rated input current	: 3,0 A
Rated output current	: 4 A

**Product data – type NPB-360-12z**

Rated output voltage	: 14,4 Vdc
Rated input current	: 4,5 A
Rated output current	: 20 A

**Product data – type NPB-360-24z**

Rated output voltage	: 28,8 Vdc
Rated input current	: 4,5 A
Rated output current	: 12 A

**Product data – type NPB-360-48z**

Rated output voltage : 57,6 Vdc  
Rated input current : 4,5 A  
Rated output current : 6 A

**TESTS****Test requirements**

EN 62368-1:2014  
EN 62368-1:2014/A11:2017

**Test result**

The test results are documented in DEKRA test file 491828300.

**Additional information**

This certificate replaces certificate No. 35-118966 REV.1 which we hereby declare invalid.

The list of components is laid down in test report 4918283.50.

**Conclusion**

The examination has confirmed that all requirements were met.

**Factory locations**

MEAN WELL (GUANGZHOU) Electronics Co., Ltd.  
No.11 Jingu South Road, Huadu District  
510890 Guangzhou Guangdong, China

MEAN WELL Enterprises Co., Ltd.  
No.28, Wuquan 3rd Rd, Wugu District  
24891 New Taipei City, Taiwan

SuZhou MEAN WELL Technology Co., Ltd.  
No.269, Changping Road, Huangdai Town, Xiangcheng District  
215152 Suzhou Jiangsu, China

Trade name : MEAN WELL stands for

