



# Test Report: XLG-200-24

---

200W Constant Voltage + Constant Current LED Driver

## ■ DESIGN VERIFY TEST

Output Function Test

Input Function Test

Protection Function Test

Component Stress Test

## ■ SAFETY & E.M.C. TEST

Safety Test

E.M.C. Test


## ■ RELIABILITY TEST

ENVIRONMENT TEST


■ DESIGN VERIFY TEST

OUTPUT FUNCTION TEST


NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	CONSTANT CURRENT REGION	16.8 V~ 24V	I/P: 230 VAC O/P: FULL LOAD Ta: 25°C	8.6V~ 24 V /230VAC
2	CURRENT ADJ. RANGE	4.15A~ 8.3A	I/P: 230 VAC I/P: 115VAC O/P: CV MIN & CV MAX-1V Ta: 25°C	3.876A~10.127A /230VAC@CV MAX-1V 3.885A~ 10.128A /230VAC@CV MIN 3.884A~ 10.126A/115VAC@CV MAX-1V 3.889A~10.128 A/115VAC@CV MIN
3	OUTPUT VOLTAGE TOLERANCE (Max)	-2% ~2%	I/P: 100VAC ~305VAC O/P: MIN LOAD—FULL LOAD Ta: 25°C	0.27 %~ 0.27 %
4	DYNAMIC LOAD	V1 : 2400 mVp-p	I/P : 230VAC O/P : (1) FULL /50% LOAD 50%DUTY / 120HZ (2) FULL /50% LOAD 50%DUTY / 1KHZ Ta : 25°C	(1) 204mVp-p (2) 286mVp-p
FULL /50% LOAD 50%DUTY / 120HZ				
FULL /50% LOAD 50%DUTY / 1KHZ				
5	LINE REGULATION (Max)	-0.5% ~ 0.5%	I/P: 110VAC~305AC O/P: FULL LOAD Ta: 25°C	0%~0 %
6	LOAD REGULATION (Max)	-1% ~ 1%	I/P: 230 VAC O/P: MIN / HALF/ FULL LOAD Ta: 25°C	0.292%~ -0.25 %
7	OVER/UNDERSHOOT TEST	< ±5%	I/P: 230 VAC O/P: FULL LOAD/Min LOAD Ta: 25°C	<5 %
8	RIPPLE & NOISE (Max)	240mVp-p	I/P: 230 VAC O/P: MIN LOAD—FULL LOAD Ta: 25°C	35mVp-p / 100% load
high frequency :		low frequency :		




9	SET UP TIME (Max)	230VAC/ 500ms 115VAC/ 1200ms	I/P: 230 VAC I/P: 115 VAC O/P:FULL LOAD Ta:25°C	230VAC/ 153 ms 115 VAC/ 203 ms
---	-------------------	---------------------------------	--	-----------------------------------



10	RISE TIME (Max)	230VAC/ 100ms 115VAC/ 100ms	I/P: 230 VAC I/P: 115 VAC O/P:FULL LOAD Ta:25°C	230VAC/ 26.8 ms 115 VAC/ 26.8 ms
----	-----------------	--------------------------------	--	-------------------------------------




11	HOLD UP TIME (Typ.)	230VAC/ 10ms 115VAC/ 10ms	I/P: 230 VAC I/P: 115 VAC O/P:FULL LOAD Ta:25°C	230VAC/ 26.8 ms 115 VAC/ 27.2 ms
----	---------------------	------------------------------	--	-------------------------------------




### INPUT FUNCTION TEST


NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	INPUT VOLTAGE RANGE	100VAC~305VAC	I/P: TESTING O/P: FULL LOAD Ta: 25°C	70V~305 V
			I/P: LOW-LINE-3VAC=97 VAC HIGH-LINE+10VAC=315 VAC O/P: FULL/MIN LOAD (PLEASE CHECK DERATING CURVE) ON: 30 Sec OFF: 30 Sec 10MIN (POWER ON/OFF NO DAMAGE)	TEST:OK
2	INPUT FREQUENCY RANGE	47HZ ~63 HZ NO DAMAGE	I/P: 100VAC~305VAC O/P: FULL~MIN LOAD Ta: 25°C	OK
3	INPUT CURRENT (TYP)	277VAC/ 0.9 A 230 VAC/ 1.1 A 115 VAC/ 2.2 A	I/P: 277VAC/230 VAC/115 VAC O/P: FULL LOAD Ta: 25°C	I= 0.76 A/277VAC I=0.88 A/ 230VAC I=1.79 A/ 115VAC
4	LEAKAGE CURRENT	<0.75mA/277AC	I/P : 277 VAC O/P : MIN LOAD Ta : 25°C	L-FG: 0.22mA N-FG:0.22mA
5	NO LOAD CONSUMPTION	<0.5W	I/P : 115VAC I/P : 230VAC O/P : NO LOAD Ta : 25°C	< 0.41W < 0.44W
6	POWER FACTOR(TYP)	0.92/277 VAC FULL LOAD 0.95/230 VAC FULL LOAD 0.97/115 VAC FULL LOAD	I/P: 230 VAC/115VAC/277VAC O/P: FULL LOAD Ta: 25°C	PF= 0.941 /277V/100%LOAD PF= 0.979 /230V/100%LOAD PF= 0.998 /115V/100%LOAD
	P.F vs LOAD			




7	EFFICIENCY (TYP)	94%	I/P: 230 VAC O/P: FULL LOAD Ta: 25°C	94.37%
---	------------------	-----	--	--------



8	INRUSH CURRENT (TYP)	230 V/ 65A COLD START  (twidh=550us measured at 50% Ipeak) COLD START	I/P: 230 VAC O/P: FULL LOAD Ta: 25°C 使用 CCH MODE TEST	I = 53.5 A / 230VAC  T50= 400 us
---	----------------------	---	--	--



9	TOTAL HARMONIC DISTORTION	THD < 10% (@load ≥ 50% / 115V, 230VAC; @load ≥ 75% / 277VAC)	I/P : 230VAC I/P : 115VAC O/P : 50% LOAD Ta : 25°C	THD: 6.23% THD: 4.78%
			I/P : 277VAC O/P : 75% LOAD Ta : 25°C	THD: 5.76%



### PROTECTION FUNCTION TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	OVER CURRENT PROTECTION	95%~ 108%	I/P: 305VAC I/P: 230VAC I/P: 110VAC O/P: TESTING Ta:25°C	102.16%/ 305VAC 102.16%/ 230VAC 102.16%/110VAC PROTECTION TYPE : Hiccup mode or constant current limiting, recovers automatically after fault condition is removed
2	OVER VOLTAGE PROTECTION	V1: 27V~ 34V	I/P: 305VAC I/P: 230VAC I/P: 100VAC O/P: MIN LOAD Ta:25°C	29.25V/ 305VAC 29.24V/ 230VAC 29.24V/ 110VAC PROTECTION TYPE : Shut down output voltage, re-power on to recover
3	OVERTEMPERATURE PROTECTION	NO DAMAGE	I/P: 305 VAC I/P: 110 VAC O/P: FULL LOAD	O.T.P Active PROTECTION TYPE : Shut down output voltage, re-power on to recover
4	SHORT PROTECTION	SHORT EVERY OUTPUT 1 HOUR NO DAMAGE	I/P: 305VAC I/P: 100 VAC O/P: FULL LOAD Ta:25°C	NO DAMAGE PROTECTION TYPE : Hiccup mode or constant current limiting, recovers automatically after fault condition is removed
5	INPUT OVER VOLTAGE (for XLG-200I only)	320 ~ 390VAC (Shut down output voltage when the input voltage exceeds protection voltage Can survive input voltage stress of 440Vac for 48 hours	I/P : TESTING O/P: FULL LOAD Ta:25°C	PASS

### COMPONENT STRESS TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	PWM Transistor ( D to S) or (C to E) <b>Peak Voltage</b>	Q3 Rated: 650V/11A	AC ON/OFF  I/P: High-Line +3V =308V I/P: Low-Line -3V = 107V  VDS: O/P: (1) Full Load (2) Output Short (3) Dynamic Load Full Load/ Min. Load 90%Duty/1KHz (4) Dynamic Load Full Load/	Q3 308VAC 107VAC (1)448V (1)460V (2)476V (2)481V (3)436V (3) 465V (4)432V (4) 461V (5)432V (5) 457V (6)436V (6) 457V (7)469V (7)477 V (8) 428V (8) 429V (9)436V (9) 449V

			<p>Min. Load 90%Duty/3KHz            (5)Dynamic Load Full Load/            Min. Load 90%Duty/5KHz            (6)Dynamic Load 100% Load/            Min. Load 50%Duty/120Hz            (7)0%→400% Load.            (8)No load            (9)LED MODE max            (10)LED MODE min</p> <p>Ta:25°C</p>	(10) 432V (10)453 V
2	PFC OUTPUT DIODE PEAK VOLTAGE TEST	D1 Rated: 9A/600V	<p>I/P:High-Line +3V =308 V            O/P: (1)Full Load            (2)Output Short            (3)Dynamic Load Full Load/            Min. Load 90%Duty/1KHz            (4)Dynamic Load 100% Load/            Min. Load 50%Duty/120Hz</p> <p>Ta:25°C</p>	<p>D1            308VAC            VDS            (1)445V            (2)465V            (3)449V            (4)449V</p>
3	Diode Peak Voltage	Q100 Rated : 63A/80V	<p>AC ON/OFF            I/P:High-Line +3V =308 V            O/P: (1)Full Load            (2)Output Short            (3)Dynamic Load Full Load/            Min. Load 90%Duty/1KHz            (4)Dynamic Load 100% Load/            Min. Load 50%Duty/120Hz            (5).NO LOAD            (6) burst mode</p> <p>Ta:25°C</p>	<p>Q100:            VDS:            (1)25.9V            (2)9.95V            (3)51.4V            (4)51V            (5)50.2V            (6)50.2V</p>
4	Control IC Voltage Test	PWM IC U2 Rated 30V	<p>I/P:High-Line +3VAC=308V            AC ON/OFF            O/P: (1)Full Load Input On/Off            (2) Output Short            (3)O.L.P            (4)O.V.P.            (5) Low Line No Load Vo(min)            (6) CV MAX            (7) CV MIN</p> <p>Ta:25°C</p>	<p>U2            (1) 25.8V            (2) 16.9V            (3) 25.8V            (4) 26V            (5) 15.7V            (6) 25.8V            (7) 25.8V</p>
5	PFC Transistor	Q1 Rated 20A/600V	<p>I/P : High-Line +3V =308V            O/P : (1) Full Load Turn on            (2) Output Short            (3) Full load continue</p> <p>Ta : 25°C</p>	<p>(1) 510 V            (2) 466 V            (3) 474 V</p>
6	Input Capacitor Voltage	C5 Rated : 100 μ / 450 V	<p>I/P : High-Line +3V =308 V            O/P: (1)Full Load input on/off            (2) Min load input on /Off            (3)Full Load /Min load Change            (4)Full load continue</p> <p>Ta : 25°C</p>	<p>(1)448V            (2)444V            (3)447V            (4)444V</p>

### SAFETY TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	WITHSTAND VOLTAGE	I/P-O/P : 3.75KVAC/min I/P-FG : 2KVAC/min O/P-FG : 1.5KVAC/min	I/P-O/P : 4.125 KVAC/min I/P-FG : 2.4KVAC/min O/P-FG : 1.8 KVAC/min Ta : 25°C	I/P-O/P : 2.351 mA I/P-FG : 2.066 mA O/P-FG : 2.329 mA NO DAMAGE
2	ISOLATION RESISTANCE	I/P-O/P : 500VDC>100MΩ I/P-FG : 500VDC>100MΩ O/P-FG : 500VDC>100MΩ	I/P-O/P : 500 VDC I/P-FG : 500 VDC O/P-FG : 500 VDC Ta : 25°C	I/P-O/P : >9999 MΩ I/P-FG : >9999 MΩ O/P-FG : >9999 MΩ
3	GROUNDING CONTINUITY	FG(PE) TO CHASSIS OR TRACE < 100 mΩ	40A / 2min Ta:25°C	13mΩ

### E.M.C TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	HARMONIC	EN61000-3-2 CLASS C	I/P : 230 VAC/50HZ O/P : FULL/50% LOAD Ta : 25°C	PASS
2	CONDUCTION	EN55015	I/P : 230 VAC/50HZ O/P : FULL LOAD Ta : 25°C	PASS Test by certified Lab
3	RADIATION	EN55015	I/P : 230 VAC/50HZ O/P : FULL LOAD Ta : 25°C	PASS Test by certified Lab
4	E.S.D	EN61000-4-2 LIGHT INDUSTRY AIR : 8KV Contact : 4KV	I/P : 230 VAC/50HZ O/P : FULL LOAD Ta : 25°C	CRITERIA A
5	E.F.T	EN61000-4-4 LIGHT INDUSTRY INPUT : 2KV	I/P : 230VAC/50HZ O/P : FULL LOAD Ta : 25°C	CRITERIA A
6	SURGE	EN61000-4-5 LIGHT INDUSTRY L-N : 4KV L,N-PE : 6KV	I/P : 230VAC/50HZ O/P : FULL LOAD Ta : 25°C	CRITERIA A
7	Test by certified Lab & Test Report Prepare. Any contradictions of the test results please refer to the latest EMC test report.			



■ **RELIABILITY TEST**

**ENVIRONMENT TEST**

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT																																																																																																												
1	TEMPERATURE RISE TEST	MODEL : XLG-200-24A 1. ROOM AMBIENT BURN-IN : 2 HRS I/P : 230VAC O/P : FULL LOAD Ta=29.1°C 2. HIGH AMBIENT BURN-IN : 2 HRS I/P : 230VAC O/P : FULL LOAD Ta=51.2°C																																																																																																														
		<table border="1"> <thead> <tr> <th>NO</th> <th>Position</th> <th>ROOM AMBIENT Ta=29.1 °C</th> <th>HIGH AMBIENT Ta=51.2 °C</th> </tr> </thead> <tbody> <tr><td>1</td><td>RTH1</td><td>60.3°C</td><td>78.8°C</td></tr> <tr><td>2</td><td>ZNR3</td><td>52.3°C</td><td>74.3°C</td></tr> <tr><td>3</td><td>BD1</td><td>55.2°C</td><td>77.0°C</td></tr> <tr><td>4</td><td>L2</td><td>53.7°C</td><td>76.0°C</td></tr> <tr><td>5</td><td>C9</td><td>53.6°C</td><td>75.5°C</td></tr> <tr><td>6</td><td>C10</td><td>52.9°C</td><td>75.2°C</td></tr> <tr><td>7</td><td>C5</td><td>52.0°C</td><td>74.0°C</td></tr> <tr><td>8</td><td>Q1</td><td>52.9°C</td><td>75.0°C</td></tr> <tr><td>9</td><td>U1</td><td>52.3°C</td><td>74.1°C</td></tr> <tr><td>10</td><td>C15</td><td>52.8°C</td><td>75.5°C</td></tr> <tr><td>11</td><td>D1</td><td>55.9°C</td><td>78.6°C</td></tr> <tr><td>12</td><td>Q2</td><td>55.8°C</td><td>78.0°C</td></tr> <tr><td>13</td><td>Q3</td><td>56.1°C</td><td>78.4°C</td></tr> <tr><td>14</td><td>R7</td><td>54.6°C</td><td>76.8°C</td></tr> <tr><td>15</td><td>U2</td><td>54.8°C</td><td>77.3°C</td></tr> <tr><td>16</td><td>D2</td><td>55.1°C</td><td>77.6°C</td></tr> <tr><td>17</td><td>T1</td><td>58.7°C</td><td>82.2°C</td></tr> <tr><td>18</td><td>C106</td><td>54.2°C</td><td>77.5°C</td></tr> <tr><td>19</td><td>C108</td><td>52.0°C</td><td>74.9°C</td></tr> <tr><td>20</td><td>LF100</td><td>52.1°C</td><td>75.1°C</td></tr> <tr><td>21</td><td>U101</td><td>56.8°C</td><td>80.1°C</td></tr> <tr><td>22</td><td>Q100</td><td>55.1°C</td><td>78.3°C</td></tr> <tr><td>23</td><td>Q101</td><td>57.6°C</td><td>81.4°C</td></tr> <tr><td>24</td><td>J102</td><td>56.8°C</td><td>80.1°C</td></tr> <tr><td>25</td><td>RTH3</td><td>50.9°C</td><td>73.4°C</td></tr> <tr><td>26</td><td>TC</td><td>49.6°C</td><td>71.5°C</td></tr> </tbody> </table>	NO	Position	ROOM AMBIENT Ta=29.1 °C	HIGH AMBIENT Ta=51.2 °C	1	RTH1	60.3°C	78.8°C	2	ZNR3	52.3°C	74.3°C	3	BD1	55.2°C	77.0°C	4	L2	53.7°C	76.0°C	5	C9	53.6°C	75.5°C	6	C10	52.9°C	75.2°C	7	C5	52.0°C	74.0°C	8	Q1	52.9°C	75.0°C	9	U1	52.3°C	74.1°C	10	C15	52.8°C	75.5°C	11	D1	55.9°C	78.6°C	12	Q2	55.8°C	78.0°C	13	Q3	56.1°C	78.4°C	14	R7	54.6°C	76.8°C	15	U2	54.8°C	77.3°C	16	D2	55.1°C	77.6°C	17	T1	58.7°C	82.2°C	18	C106	54.2°C	77.5°C	19	C108	52.0°C	74.9°C	20	LF100	52.1°C	75.1°C	21	U101	56.8°C	80.1°C	22	Q100	55.1°C	78.3°C	23	Q101	57.6°C	81.4°C	24	J102	56.8°C	80.1°C	25	RTH3	50.9°C	73.4°C	26	TC	49.6°C	71.5°C		
NO	Position	ROOM AMBIENT Ta=29.1 °C	HIGH AMBIENT Ta=51.2 °C																																																																																																													
1	RTH1	60.3°C	78.8°C																																																																																																													
2	ZNR3	52.3°C	74.3°C																																																																																																													
3	BD1	55.2°C	77.0°C																																																																																																													
4	L2	53.7°C	76.0°C																																																																																																													
5	C9	53.6°C	75.5°C																																																																																																													
6	C10	52.9°C	75.2°C																																																																																																													
7	C5	52.0°C	74.0°C																																																																																																													
8	Q1	52.9°C	75.0°C																																																																																																													
9	U1	52.3°C	74.1°C																																																																																																													
10	C15	52.8°C	75.5°C																																																																																																													
11	D1	55.9°C	78.6°C																																																																																																													
12	Q2	55.8°C	78.0°C																																																																																																													
13	Q3	56.1°C	78.4°C																																																																																																													
14	R7	54.6°C	76.8°C																																																																																																													
15	U2	54.8°C	77.3°C																																																																																																													
16	D2	55.1°C	77.6°C																																																																																																													
17	T1	58.7°C	82.2°C																																																																																																													
18	C106	54.2°C	77.5°C																																																																																																													
19	C108	52.0°C	74.9°C																																																																																																													
20	LF100	52.1°C	75.1°C																																																																																																													
21	U101	56.8°C	80.1°C																																																																																																													
22	Q100	55.1°C	78.3°C																																																																																																													
23	Q101	57.6°C	81.4°C																																																																																																													
24	J102	56.8°C	80.1°C																																																																																																													
25	RTH3	50.9°C	73.4°C																																																																																																													
26	TC	49.6°C	71.5°C																																																																																																													
2	LOW TEMPERATURE TURN ON TEST	TURN ON AFTER 2 HOUR	I/P : 305VAC/110VAC O/P : 100% LOAD Ta= -45°C / -35°C	TEST : OK																																																																																																												
3	HIGH HUMIDITY HIGH TEMPERATURE HIGH VOLTAGE TURN ON TEST	AFTER 12 HOURS IN CHAMBER ON CONTROL 50°C NO DAMAGE	I/P : 305VAC O/P : FULL LOAD Ta=50°C HUMIDITY= 95 %R.H	TEST : OK																																																																																																												
4	TEMPERATURE COEFFICIENT	±0.03 %/°C (0~60°C)	I/P : 230 VAC O/P : FULL LOAD	±0.01 %/°C (0~60°C)																																																																																																												
5	STORAGE TEMPERATURE TEST	-40°C ~ +90°C	1. Thermal shock Temperature : -50°C ~ +125°C 2. Temperature change rate : 25°C / MIN 3. Dwell time low and high temperature : 30 MIN/EACH 4. Total test cycle : 200CYCLE 5. Input/Output condition : STATIC TEST : OK																																																																																																													

6	THERMAL SHOCK TEST	-40~+50°C	1. Thermal shock Temperature : -45°C~ +55°C 2. Temperature change rate : 25°C / MIN 3. Dwell time low and high temperature : 30 MIN/EACH 4. Total test cycle : 16CYCLE 5. Input/Output condition : 15cycle:230VAC/ FULL LOAD AC on 3 sec/AC off 1 sec TEST 1cycle:230VAC/ FULL LOAD Burn In Test TEST : OK
7	VIBRATION TEST	10~ 500Hz, 5G 12min./1cycle, period for 72min. each along X, Y, Z axes	1 Carton & 1 Set (1) Waveform : Sine Wave (2) Frequency : 10~500Hz (3) Sweep Time : 12min/sweep cycle (4) Acceleration : 6G (5) Test Time : 72min in each axis (X.Y.Z) (6) Ta : 25°C TEST : OK
8	CAPACITOR LIFE CYCLE	XLG-200-24 : SUPPOSE C106 IS THE MOST CRITICAL COMPONENT (1) I/P : 230VAC O/P : FULL LOAD Tc= 75 °C LIFE TIME (2) I/P : 230VAC O/P : 75% LOAD Tc= 75 °C LIFE TIME (3) I/P : 230VAC O/P : 50% LOAD Tc= 75 °C LIFE TIME	(1) 49948 HRS (2) 71023 HRS (3) 91592 HRS
9	MTBF	Conducted by Parts Stress Analysis Prediction 2300.1K hrs min. Telcordia SR-332 (Bellcore); 200.7K hrs min. MIL-HDBK-217F (25°C)	
10	Ongoing Reliability Test	I/P : 230VAC O/P : FULL LOAD TA=50°C Demonstration Mean Time Between Failure : 50,000 hours	

TEST RESULT	TESTER	REVIEW	APPROVAL
PASS	WUWQ/ZHOUB	WENF	LIUWY